

City of Robinson

WWTF



Telephone: (618) 544-8110 Fax: (618) 544-4300

ROBINSON, ILLINOIS 62454

E.H. Baare Corporation
500 Heath Toffee Avenue
Robinson, Illinois 62454

July 06, 2021

Attention: Mr. Travis Crumrin

Subject: Notice of Violation
Permit #: RB20
Ordinance #: 2020-0-30

Mr. Crumrin:

Per Local Limits compliance testing performed by the City of Robinson on 6/16/21, the sample revealed a Phosphorus level of 21 mg/L and an Iron level of 9.58 mg/L. These two levels are above the limits set forth as Local Limits in Permit Number RB20. The Phosphorus limit is 20 mg/L and Iron is 4.20 mg/L.

Interim Conditions:

1. E.H. Baare shall take appropriate steps necessary to keep the discharge levels of these constituents below their respective limits.
2. Any future discharges from E.H. Baare that show non-compliance shall be subject to fines and further enforcement action.

If you have any questions concerning this notice of violation of the City of Robinson Industrial Pretreatment Program, please feel free to contact me at (618) 562-0040.

Sincerely,

CITY OF ROBINSON

Lawrence E. Quick
Superintendent of Public Works

cc: Mayor Pethtel
WWTF Committee
City Clerk
file